

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:34 am

**PWS ID:** UTAH02013      **Name:** PLYMOUTH TOWN WATER SYSTEM

**Legal Contact:** TOWN OF PLYMOUTH      **Rating:** Approved  
BRIAN SCOTT STARR      **Rating Date:** 05/06/2010

**Address:** TOWN HALL, PO BOX 180      **Activity Status:** Active  
PLYMOUTH, UT 84330

**Phone Number:** 435-452-2365

**City Served (Area):**

**County:** BOX ELDER COUNTY

**System Type:** Community      **Last Inv Update:** 01/06/2011      **Avg Daily Prod:**

**Activity Status Cd:** Active      **Last Snty Srv Dt:** 06/11/2009      **Total Dsgn Cap:**

**Population:** 386      **Surveyor:** DAVID F HANSEN      **Total Emerg Cap:**

**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	STARR, BRIAN SCOTT	MANAGER	435-458-3646	435-452-2365	bcstarr@frontiernet.net

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	112
			112 Total Svc Connections

### Storage

**Total Storage:** 249,000 GAL      **Number of Units:** 3      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	100,000 GAL	Concrete		A	
ST002	STORAGE FACILITY ST002	Ground	100,000 GAL	Concrete		A	
ST003	STORAGE FACILITY ST003	Ground	49,000 GAL	Concrete		A	

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	TUNNEL SPRING CHLORINATOR		A	
TP002	PLYMOUTH TOWN CHLORINATOR		P	

### Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	TUNNEL SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	GUNSIGHT SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	SOAPSTONE SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.

---

## Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS004	CHOKECHERRY SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS005	CITY WELL #1	Inactive	WL	10	25 GPM		Yes	GW	Other		
WS006	CITY WELL #2	Active	WL	12	425 GPM	425 GPM	Yes	GW	Permanent	1/1 to 12/31	

*\*Reports measured flow for wells, approved design capacity for all other sources.*